

Record of Water Well

4042 Vermont

Case # 310 604

Indiana Department of Natural Resources

Reference Number 180630	Driving directions to well SPEEDWAY		Date completed Sep 22, 1961	
Owner-Contractor	Name	Address	Telephone	
Owner	CHAS GREEN	4042 W VERMONT		
Driller	MANFORD DILAN	841 W SUMNER AVE		
Operator	NOLES CREED	License: null		
Construction Details				
Well	Use: Home	Drilling method: Cable Tool	Pump type:	
	Depth: 35.0	Pump setting depth:	Water quality:	
Casing	Length: 35.0	Material:	Diameter: 4.5	
Screen	Length: 0.5	Material:	Diameter: 3.0 Slot size: 6	
Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for 1.5 hrs.	Bail Test rate: gpm for hrs.	
	Drawdown: 0.0 ft.	Static water level: 20.0 ft.	Bailer Drawdown: ft.	
Grouting Information	Material:	Depth: from to		
	Installation Method:	Number of bags used:		
Well Abandonment	Sealing material:	Depth: from to		
	Installation Method:	Number of bags used:		
Administrative	County: MARION		Township: 15N Range: 3E	
	Section: SE of the SW of the NW of Section 5		Topo map: INDIANAPOLIS WEST	
	Grant Number:			
	Field located by:		on:	
	Courthouse location by:		on:	
	Location accepted w/o verification by:		on:	
	Subdivision name:		Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL: Ft S of NL:	
	Ground elevation:	Depth to bedrock:	Bedrock elevation: Aquifer elevation:	
	UTM Easting:		UTM Northing:	
Well Log	Top	Bottom	Formation	
	0.0	5.0	YEL CLAY	
	5.0	18.0	SANDY HARDPAN	
	18.0	25.0	DRY SAND	
	25.0	35.0	S&G	

Comments